

Manufacturer: Jacksons Fencing

Web: www.jacksons-security.co.uk

Tel: +44 (0)1233 750393 | 0800 953 3699

Product Reference: EUROGUARD® REGULAR

Service Life of Fencing

Steel fencing and gates designed and manufactured to be fit for purpose and providing a minimum 25 year guarantee, delivering the lowest whole life cost and significantly reduced carbon footprint.

Fencing & Posts:

1525mm High, Post Dimensions: 60 x 40mm (3034mm Post Centres)

1810mm High, Post Dimensions: 60 x 40mm (3034mm Post Centres)

2010mm High, Post Dimensions: 60 x 40mm (3034mm Post Centres)

2410mm High, Post Dimensions: 80 x 60mm (3054mm Post Centres)

** Delete above as required*

Mesh:

200 x 45mm mesh, 5mm wires (wire measure prior to coating) with 2 - 4 reinforcing folds according to height, Galfan® Zinc alloy treated as standard. Vertical wires are at 50mm centres therefore panel has 61 vertical wires.

Posts:

Posts are rectangular hollow section steel hot dip galvanised inside and out to BS EN 1461 as standard and supplied with flat post caps in black polypropylene.

Over length set in concrete as standard
Base plated to bolt down onto concrete
Cranked to suit wall mounting
** Delete above post options as required*

Fixings:

Unique vandal-proof panel to post fixing

Finish / Colour:

Galfan® zinc alloy coated to BS EN 10244-2:2009 class A as standard. Posts supplied galvanised inside and out to BS EN 1461 as standard.

Galfan® zinc alloy coated to BS EN 10244-2:2009 class A as standard. Posts supplied galvanised inside and out to BS EN 1461 as standard then polyester powder coated with Akzo Nobel Interpon coating in standard [Black RAL 9005] [Green RAL 6005].

Galfan® zinc alloy coated to BS EN 10244-2:2009 class A as standard. Posts supplied galvanised inside and out to BS EN 1461 as standard then polyester powder coated with Akzo Nobel Interpon coating in special [Insert RAL/BS],

Marine coating required as installation is within 500m of salt water or estuary.

** Delete above as required*

Setting Posts

Holes: Excavate neatly and with vertical sides.

Setting posts as standard in concrete: To BS 8500-2.

[Mix: Designated concrete not less than GEN1 or Standard prescribed concrete not less than ST2.] [Alternative mix for small quantities: 50kg Portland cement to 150kg fine aggregate to 250kg, 20mm nominal maximum size coarse aggregate, medium workability.] [Admixtures: Do not use]

Filling: Position post/strut and fill hole with concrete to not less than the specified depth, well rammed as filling proceeds and consolidated. Backfilling of holes not completely filled with concrete: Excavated material, well rammed and consolidated.

NOTES:

For more information please contact Jacksons Fencing. We reserve the right to alter specification within this document at any time.